

FIRE EXTINGUISHERS (Very Short Training)

Placement and Use of Fire Extinguishers

Goals:

- *Identify portable fire extinguishers.
- *Safely use portable fire extinguisher to put out small fires.
- *Select proper locations for placement of portable fire extinguishers.
- *Maintain inspection logs for portable fire extinguishers.

***Attached Fire Extinguisher Fact Sheet**

***Safety Tips**

- *Fire extinguisher location and placement information.
- *Types of fire extinguishers A, B, C, D and K requirements

Notes:

Fire extinguishers are a valuable tool to prevent fires from immediately getting out of control.

Proper placement of fire extinguishers is imperative for access in an emergency.

Knowledge and training is important for all employees working in a federal workplace.



FIRE EXTINGUISHER LOCATION AND PLACEMENT

Code officials are charged with ensuring that occupancies are properly outfitted with fire extinguishers and that they are placed in the right locations. This resource identifies which occupancies require extinguishers and where they should be placed within them. It also outlines related fire extinguisher requirements in NFPA® 10, *Standard for Portable Fire Extinguishers*.

Occupancy Requirements

Fire extinguishers **are required** in the following occupancy types:

Ambulatory health care	Hotel and dormitory	Health care
Apartments	Industrial	Educational
Assemblies	Lodging and rooming	Storage
Businesses	Mercantile	Detention and correctional
Day care	Occupancies in special structures	Residential board and care

Fire extinguishers **are not required** in one- and two-family dwellings. For more information on occupancy requirements, see Table 13.6.1.2 of NFPA 1, *Fire Code* (2018).

Where and How Should Extinguishers Be Located?

Fire extinguishers that are placed correctly can be accessed more quickly to help control a fire until the fire department arrives. Fire extinguishers are not intended to be a substitute for evacuating the building safely and quickly. Two key factors for locating extinguishers are that they should be accessible and visible.

Accessible

Extinguishers should be placed where they are readily accessible in the event of a fire, which typically includes normal paths of travel.

Visible

If visual obstructions cannot be avoided, then arrows, lights, or signs are needed to help indicate where a fire extinguisher is located.

If extinguisher weighs **more than 40 lb (18.14 kg) ...**

- ▶ **Top of extinguisher** cannot be more than **3.5 ft (1.07 m)** from the ground
- ▶ **Bottom of extinguisher** must be at least **4 in. (102 mm)** off the ground



If extinguisher weighs **less than 40 lb (18.14 kg) ...**

- ▶ **Top of extinguisher** cannot be more than **5 ft (1.53 m)** from the ground
- ▶ **Bottom of extinguisher** must be at least **4 in. (102 mm)** off the ground

In both cases, this includes extinguishers in cabinets, but it does not include wheeled extinguishers.



FIRE EXTINGUISHER LOCATION AND PLACEMENT CONTINUED

Class A, B, C, D, and K Extinguisher Requirements

A portable extinguisher must match the fire that is being fought. There are five classes of fires. Extinguishers are labeled with letters and symbols for the classes of fires they can put out. While these requirements apply to all portable fire

extinguishers, different location requirements exist for Class A, B, C, D, and K extinguishers. See Figure B.1.1 of NFPA 10 for a recommended marking system that can be used to illustrate the uses and nonuses of fire extinguishers on a single label.

Extinguisher Requirements Table

Extinguisher Class and Letter-Shaped Symbol Markings	Extinguisher Use	Location Requirements
<p>A Ordinary Combustibles</p>	<ul style="list-style-type: none"> Required anywhere ordinary combustibles are present. Fires involve materials such as wood, cloth, and paper. 	<ul style="list-style-type: none"> Requirements for fire extinguisher size and spacing based on your hazard level are located in Table 6.2.1.1 of NFPA 10. To determine the minimum number of extinguishers needed, divide the total floor area by the maximum floor area to be protected per extinguisher. Travel distance to the extinguisher can't be more than 75 ft (22.9 m).
<p>B Flammable Liquids</p>	<ul style="list-style-type: none"> Required for locations where there is the potential for flammable liquid fires. Fires involve flammable liquids such as gasoline, oil, and some paints and solvents. 	<ul style="list-style-type: none"> Table 6.3.1.1 in NFPA 10 includes information about the maximum travel distance to extinguishers based on the type of hazard (low, moderate, or high) and the extinguisher rating. Travel distance to the extinguisher cannot be more than 30 ft to 50 ft (9.1 m to 15.25 m), depending on the type of hazard and extinguisher rating.
<p>C Electrical Equipment</p>	<ul style="list-style-type: none"> Required in areas where energized electrical equipment may be encountered. Fires involve energized electrical equipment. 	<ul style="list-style-type: none"> A Class C rating is only put on extinguishers that already have a Class A or Class B rating. A Class A, Class B, or Class A & B extinguisher gets measured to see if it conducts electricity and if it doesn't, then it gets a Class C rating.
<p>D Combustible Metals</p>	<ul style="list-style-type: none"> Required in areas where there is a potential for fires involving combustible metals. Fires involve combustible metals, such as magnesium and sodium. 	<ul style="list-style-type: none"> Should not be placed more than 75 ft (22.9 m) of travel distance from a potential hazard.
<p>K N/A</p>	<ul style="list-style-type: none"> Used where there is a potential for fires involving combustible cooking components. Fires involve cooking oils used in commercial cooking equipment. 	<ul style="list-style-type: none"> Should not be located further than 30 ft (9.1 m) from the hazard.

For More Information Visit nfpa.org/10.

IT'S A BIG WORLD. LET'S PROTECT IT TOGETHER.



This material contains some basic information about NFPA 10, Standard for Portable Fire Extinguishers. It identifies some of the requirements in these documents as of the date of publication. This material is not the official position of any NFPA Technical Committee on any referenced topic, which is represented solely by the NFPA documents on such topic in their entirety. For free access to the complete and most current version of all NFPA documents, please go to nfpa.org/docinfo. References to "Related Regulations" or "Code/Standard for Reference" is not intended to be a comprehensive list. NFPA makes no warranty or guarantee of the completeness, accuracy, or reliability of the information in this material and disclaims liability for personal injury, property and other damages of any nature whatsoever, from the use of or reliance on this information. In using this information, you should rely on your independent judgment and, when appropriate, consult a competent professional.
© 2019 National Fire Protection Association / May 2019